





EXISTING IDEC CAMPUS



EXISTING PLAZA TO REMAIN

WIND TURBINE  
COLOR TO COMPLIMENT PLAZA

PEDISTAL CONCRETE BASE

SCOPE OF WORK and IMPROVEMENTS PROPOSED

PROVIDE CLEAN ENERGY BY WIND GENERATION AT EXISTING IDEC SITE  
PROVIDE ENERGY SAVINGS THROUGH INTEGRATION OF ASCETICALLY PLEASING,  
PEDESTRIAN SCALED WIND TURBINES AT EXISTING PLAZA LOCATION.  
SMALL CLUSTER OF 6 TURBINES PROPOSED AT 100 FEET FROM STREETS.

INDEX OF DRAWINGS

WT-1	COVER SHEET / INDEX
WT-2	SITE PLAN
WT-3	DATA SHT. ELECTRICAL
WT-4	FOUNDATION
WT-5	FOUNDATION DESIGN
WT-6	FOUNDATION DESIGN
WT-7	LATERAL ANALYSIS
WT-8	LATERAL ANALYSIS / TOWER ANALYSIS
WT-9	TOWER ANALYSIS

CONTRACTOR CONTACT

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com



3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682  
License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 8 . 21 . 15



TURBINE TYPICAL IMAGES

COVER SHEET  
/ INDEX

WT-1





3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682

License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com


idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 7 . 14 . 15

NORTH

SITE PLAN

WT-2








Technical Data Sheet - *Proprietary & Confidential*  
**Windspire® Wind Turbine**  
2.0kw and 1.2kW - Standard (30 ft.)  
April 2010

Material Specifications:

Mechanical Item	Size	Grade
Top Shaft:	3.5" OD x 0.120" Wall x 230" Lg.	Steel, ASTM A513 Type 5
Bottom Shaft:	3.5" OD x 0.500" Wall x 114" Lg.	Steel, ASTM A513 Type 5
Tower:	8.625" OD x 0.188" Wall x 84" Lg.	Steel, ASTM A500 Grade B
Base Plate:	10" sq. x 1" Thick	Steel, ASTM A36
Anchor Bolts:	(4) M20 x 1m Length (4.5" projection)	Steel, ISO 898.1 - Class 8.8
Airfoils:	5" Chord x 78" Length	Aluminum, 6063-T6
Airfoil Struts:	1.5" Width x 0.25" Thick	Aluminum, 6061-T6
Elastomer Dampers:	2" OD x 0.75" ID x 0.125" Thick	Fabreeka Washer - (5) at each anchor bolt (4 below, 1 above base plate)




Cut-In Wind Speed = 8.5 mph (200 rpm)  
Cut-Out Wind Speed = 31 mph (420 rpm)  
**Design Peak Gust = 105 mph**  
Peak Lateral Force (105mph) = 757 lbs.  
Peak Overturing Moment (105mph) = 13,003 lbs\*ft  
Approx. Weight = 630 lbs  
  
Rated Power (RP) = 1,200 Watts  
Wind Speed @ RP = 24 mph  
  
1st Resonance Mode = 60 rpm (+/-)  
2nd Resonance Mode = 280 rpm (+/-)


D<sub>rot</sub> = 48 in  
L<sub>rot</sub> = 240 in  
L<sub>ast</sub> = 78 in  
L<sub>ast\_ast</sub> = 46 in  
L<sub>ast\_ah</sub> = 16 in  
H<sub>rot</sub> = 120 in  
H<sub>gen</sub> = 108 in  
H<sub>bp</sub> = 96 in  
H<sub>t</sub> = 12 in (adjustable with engineering)  
ABsp = 8 in

**Note:** Product variations, revised base connections or additional connections, and/or removal of Fabreeka dampening washers will effect the rotordynamics and will result in voiding of the warranty and damage to the unit. Prior to any revisions or modifications, consult with engineering department.

DATA SHEET



TURBINE LAYOUT



ELECTRICAL CONCEPT DIAGRAM



3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682

License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 7 .14 . 15

DATA SHT.  
ELECTRICAL

WT-3



**GENERAL:**

PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE APPROPRIATE UTILITY LOCATING SERVICE TO VERIFY LOCATION OF UNDERGROUND UTILITIES. THE CONTRACTOR SHALL NOTIFY THE OWNER IMMEDIATELY IF ANY UNIDENTIFIED EXISTING UNDERGROUND UTILITIES ARE DISCOVERED.

ALL WORK SHALL CONFORM TO THE MINIMUM STANDARDS OF THE FOLLOWING CODES:

2006 INTERNATIONAL BUILDING CODE (IBC)

AND ANY OTHER REGULATING AGENCIES WHICH MAY HAVE AUTHORITY OVER ANY PORTION OF THE WORK.

CONTRACTOR TO PROVIDE PROPER SHORING/BRACING WHERE NEEDED DURING CONSTRUCTION ACTIVITIES.

**FOUNDATIONS:**

MAXIMUM ALLOWABLE FOUNDATION SOIL BEARING PRESSURE = 1500 PSF (72 KPa) FOUNDATIONS SOILS SHALL BE FREE OF ORGANIC SILTS, ORGANIC CLAYS, OR PEAT.

FOR FROST PROTECTION, THE BOTTOM OF ALL EXTERIOR FOOTINGS SHALL BE A MINIMUM OF 24" (0.610m) BELOW ADJACENT FINISHED GRADE OR GREATER DEPTH DEPENDING UPON THE LOCAL JURISDICTION.

ALL DISTURBED SOILS SURROUNDING FOOTINGS SHALL BE MOISTURE CONDITIONED AND COMPACTED IN 12" (0.305m) LIFTS, TO REACH 95 PERCENT OF THE MAXIMUM DENSITY AS DETERMINED BY ASTM D1557.

BRACE SONOTUBE OR FORM WALLS AS REQUIRED DURING BACKFILLING OPERATIONS.

**CONCRETE:**

ALL CONCRETE WORK SHALL CONFORM TO THE LATEST EDITION OF ACI 318, EXCEPT AS MODIFIED BY THE FOLLOWING SUPPLEMENTAL REQUIREMENTS:

ALL FOUNDATION CONCRETE SHALL BE NORMAL WEIGHT CONCRETE.

CONCRETE MIX DESIGN SHALL BE ESTABLISHED IN ACCORDANCE WITH CHAPTER 5 OF ACI 318.

CEMENT II OR I/II PER ASTM C-150

MAXIMUM SLUMP

3 INCHES (0.076m) - PRIOR TO ADDITION OF WATER-REDUCING ADMIXTURE

8 INCHES (0.203m) - WITH ADDITION OF WATER-REDUCING ADMIXTURE

IF SULFATE CONCENTRATIONS IN SOILS ARE GREATER THAN 0.16% (OR ANTICIPATED TO BE GREATER THAN) TYPE V CEMENT SHALL BE USED.

**ADMIXTURES**

1. FLYASH PER ASTM C-618

2. AIR ENTRAINING PER ASTM C-260

MAXIMUM SIZE COARSE AGGREGATE: 1 INCH (0.025m) PER ASTM C-33

28-DAY COMPRESSIVE STRENGTHS (f'c):

1. FOUNDATIONS = 3000 PSI (20,700 KPa) - FOR WORKABILITY, NOT STRENGTH

2. CONCRETE DESIGN STRENGTH = 2500 PSI (17,200 KPa) - NO SPECIAL INSPECTION

**REINFORCEMENT FOR CONCRETE:**

1. ALL REINFORCING SHALL BE SUPPORTED IN FORMS SPACED WITH NECESSARY ACCESSORIES AND SHALL BE SECURELY WIRED TOGETHER IN ACCORDANCE WITH CRSI "MANUAL OF STANDARD PRACTICE" (1986)

2. DEFORMED BARS - ASTM A615, GRADE 60 KSI (420 MPa)

**MINIMUM REINFORCEMENT LAP = 44 BAR DIAMETERS**

**MINIMUM CONCRETE COVER OVER REINFORCEMENT:**

CONCRETE CAST AGAINST EARTH = 3 INCHES (0.076m)

CONCRETE EXPOSED TO EARTH OR WEATHER = 1 1/2 INCHES (0.038m)

ALL CONCRETE SHALL BE MECHANICALLY VIBRATED INTO FOUNDATIONS AND FORMS


**STRUCTURAL AND MISCELLANEOUS STEEL:**


ALL STRUCTURAL STEEL WORK SHALL CONFORM TO THE AISC AND AWS SPECIFICATIONS.


ALL TOWER, BASE PLATE, AND WIND TURBINE DESIGNS BY WINDSPIRE ENERGY.

PROVIDE E70XX ELECTRODES FOR ALL WELDS, IN ACCORDANCE WITH AWS D1.4.

ISO 886-1, CLASS 8.8 GALV. OR EQUAL, BOLTS FOR ALL STEEL TO FOUNDATION CONNECTIONS.



FOUNDATION NOTES		<b>35' WINDSPIRE v.a.w.t.</b> TYPICAL FOOTINGS (1500 PSF MIN. SOIL BEARING CAPACITY)		5450 LOUIE LANE RENO, NV 89511 (775) 852-0200	WWW.WINDSPIREENERGY.COM
DATE: OCT. 11, 2010	DENNIS MONTGOMERY, P.E.				
REV. B (#10006)	SHEET: 1 OF 4				



**NON-CONSTRAINED FOUNDATION SECTION VIEW**  
SCALE: N.T.S.

**DESIGN CRITERIA:**

1. A SITE SPECIFIC DESIGN COMPARISON IS RECOMMENDED TO VERIFY DESIGN CRITERIA.

2. 2006 INTERNATIONAL BUILDING CODE (IBC).

3. DESIGN LOADS

A. VERTICAL LOAD

1. DEAD LOAD = 750 LBS (3.336 KN)

4. IBC DESIGN SEISMIC LOAD

A. SEISMIC DESIGN CATEGORY = F

B. SITE CLASS = D

C. SEISMIC RESPONSE COEFFICIENTS:

SDS= 2.0

SD1= 1.3

D. BASIC SEISMIC FORCE RESISTING SYSTEM

R= 2.5

SYSTEM: INVERTED PENDULUM SYSTEM

E. DESIGN BASE SHEAR:

V= 0.571W

F. ANALYSIS PROCEDURE:


EQUIVALENT LATERAL FORCE

5. IBC DESIGN WIND LOAD (ASCE 7-05 CODE):


A. WIND SPEED, 3 SEC. GUST = 105 MPH (47 M/S)


B. EXPOSURE = C


C. WIND FORCE GOVERNS LATERAL LOADING




**FOUNDATION PLAN VIEW**  
SCALE: N.T.S.




FOUNDATION DETAIL - OPTION #1		<b>35' WINDSPIRE v.a.w.t.</b> TYPICAL FOOTINGS (1500 PSF MIN. SOIL BEARING CAPACITY)		5450 LOUIE LANE RENO, NV 89511 (775) 852-0200	WWW.WINDSPIREENERGY.COM
DATE: OCT. 11, 2010	DENNIS MONTGOMERY, P.E.				
REV. B (#10007)	SHEET: 2 OF 4				




**ROTOR - PLAN VIEW**




**STANDARD TOWER (48' HT.)**

CAD GENERATED DRAWING DO NOT MANUALLY UPDATE			5450 LOUIE LN   RENO, NV 89511   775.852.0200 WWW.WINDSPIREENERGY.COM	TITLE: <b>WINDSPIRE 1.2KW 30FT STANDARD UNIT</b>	SIZE <b>A</b>	DWG. NO. <b>800040</b>	REV <b>A</b>
UNLESS OTHERWISE SPECIFIED:							
DIMENSIONS ARE IN INCHES							
TOLERANCES:	CHECKED	NAME	DATE				
FRACTIONAL: ±	ENG APPR.						
ANGULAR: MACH ± BEND ±	MFG APPR.						
TWO PLACE DECIMAL: ±							
THREE PLACE DECIMAL: ±							
INTERPRET GEOMETRIC TOLERANCING PER:							
MATERIAL:	COMMENTS:						
FINISH:							
DO NOT SCALE DRAWING							



**TOWER BOLTS**  
N.T.S. (30' TOTAL HT.)

THIS DOCUMENT CONTAINS INFORMATION PROPRIETARY AND CONFIDENTIAL TO WINDSPIRE ENERGY. BY ACCEPTING DELIVERY, RECIPIENT AGREES TO RETAIN IT IN CONFIDENCE AND NOT DISCLOSE IT TO OTHERS OR USE IT FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT WAS DELIVERED, AND PROMPTLY RETURN IT UPON REQUEST.

CAD GENERATED DRAWING DO NOT MANUALLY UPDATE			5450 LOUIE LN   RENO, NV 89511   775.852.0200 WWW.WINDSPIREENERGY.COM	TITLE: <b>ANCHOR &amp; TOWER FASTENERS STANDARD TOWER</b>	SIZE <b>B</b>	DWG. NO. <b>800040</b>	REV <b>A</b>
UNLESS OTHERWISE SPECIFIED:							
DIMENSIONS ARE IN INCHES							
TOLERANCES:	CHECKED	NAME	DATE				
FRACTIONAL: ±	ENG APPR.						
ANGULAR: MACH ± BEND ±	MFG APPR.						
TWO PLACE DECIMAL: ±							
THREE PLACE DECIMAL: ±							
INTERPRET GEOMETRIC TOLERANCING PER:							
MATERIAL:	COMMENTS:						
FINISH:							
DO NOT SCALE DRAWING							

(6) BOLT, M20-2.5x65, HEX HD., ZINC, C8.8 (#500124)
(5) FABREEKA WASHER, 22mm I.D. x 50mm O.D. x 3.2mm THICK (#500171)
(4) NUT, M20-2.5x20, NYLOC HEX HD., ZINC, C8.8 (#500125)
(3) TREADED ROD, M20-2.5x1m, ZINC, C8.8 (#500121)
(2) WASHER, 21mm I.D. x 50mm O.D. x 3.4mm, ZINC (#500138)
(1) NUT, M20-2.5x16, HEX HD., ZINC, C8.8 (#500189)



3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682

License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 7 . 14 . 15

FOUNDATON

WT-4





3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682  
  
License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 7 . 7 . 15



Foundation Analysis  
For  
30 FOOT WINDSPIRE (1.2KW)  
  
April 2, 2010



Prepared by:  
  
Windspire Energy  
5450 Louie Lane  
Reno, NV 89511  
Phone: (775) 852-0200  
Fax: (775) 201-0467  
www.WindspireEnergy.com

Dennis Montgomery, P.E.  
NCEES #31559

Windspire Energy Proprietary & Confidential – Distribution allowed only with written approval of Windspire Energy.  
Intended for Windspire Energy Dealer’s use in obtaining building permits and associated project approvals.



Windspire Energy  
5450 Louie Lane  
Reno, NV 89511  
www.WindspireEnergy.com  
  
Phone (775) 852-0200  
Fax (775) 201-0467

Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	As Stated	Designed	DLM	Date	04/2010
Item	Foundation Design	Checked		Date	

Design Codes / Specifications:  
2006 International Building Code  
ASCE 7-05 - Minimum Design Loads for Buildings and Other Structures  
Wind Speed: 105 mph (47 m/s)  
Exposure Category: C  
Structure Category: II  
Soils & Foundations (IBC Section 18)  
Allowable Soil Bearing Pressure: 1,500 psf (assumed worst case soils)  
Allowable Soil Lateral Pressure: 100 psf/ft (assumed worst case soils)  
200 psf/ft (with increase per IBC 1804.3.1)

Pole Foundation Analysis Summary:	
Static Load Case (105 mph):	
Rotor Force @ 20' Ht = 665 lbf (2958 N)	
Base Pole @ 5' Ht. = 92 lbf (409 N)	
Pole Foundation Size:	
Opt. #1 - Nonconstrained Pole Foundation: 2'-0" Diam. x 7'-0" Depth	
Opt. #2 - Constrained* Pole Foundation: 2'-0" Diam. x 5'-6" Depth	
Opt. #3 - Square Pad Foundation: 4'-9" Sq. x 1'-3" Depth with 2'-0" Diam. Pedestal	



Windspire Energy  
5450 Louie Lane  
Reno, NV 89511  
www.WindspireEnergy.com  
  
Phone (775) 852-0200  
Fax (775) 201-0467

Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006	Designed	DLM	Date	04/2010
Item	Non-Constrained Foundation Option #1	Checked		Date	

Pole Foundation Embedment:

Lateral Force (P): 688 lbs (Including base pole wind load transposed to 20' height)

Force Height (h): 20 ft

Footing Diameter (b): 2 ft

Assumed Fig. Depth (d): 7.0 ft

Soil Lateral Pressure (Sb): 200 psf/ft (Increased per IBC 1804.3.1, allowing 0.5" displacement)

Max. Soil Lateral Pressure: 3000 psf (IBC 1804.3.1)

$S_1 = 468.864 \text{ psf } (1/3"d"Sb)$

$A = 1.7 \text{ } (2.34"P/(S_1"b))$

$d = 7.0 \text{ ft } (IBC \text{ Eq. 18-1, REQUIRED DEPTH) } d=0.5"A*(1+(1+(4.36"h/A))^{0.5})$

Pole Foundation: 2'-0" Diam. x 7'-0" Depth



Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

**idec**  
1175 Elko Dr.  
Sunnyvale, CA


Date 7 . 14 . 15

# FOUNDATION DESIGN

WT-6

\*For constrained condition, concrete or pavement slab is required at all sides of pole foundation

**Square Pad Foundation: 4'-9" Sq. x 1'-3" Depth with 2'-0" Diam. Pedesta**

		<b>Windspeed Energy</b> 5450 Louie Lane Reno, NV 89511 <a href="http://www.WindspeedEnergy.com">www.WindspeedEnergy.com</a>		Phone (775) 852-0200 Fax (775) 201-0461	
<b>Project</b>	<b>30 FL WINDSPIRE (1.2KW)</b>	<b>Project No.</b>		<b>Sheet</b>	
<b>Code(s)</b>	<b>IBC 2006, ACI 318-08</b>	<b>Designed</b>	<b>DLM</b>	<b>Date</b>	<b>04/20/10</b>
<b>Item</b>	<b>Anchor Bolt Design</b>	<b>Checked</b>		<b>Date</b>	

**Design Codes / Specifications:**

2006 International Building Code  
 ASCE 7-05 - Minimum Design Loads for Buildings and Other Structures


Wind Speed: 105 mph (47 m/s)  
 Exposure Category: 'C'  
 Structure Category: II

**Anchor Bolt Specifications**

ISO 898-1 Class 8.8  
 Min. Yield Stress: 95 ksi (660 Mpa)  
 Min. Ultimate Stress: 120 ksi (830 Mpa)

<p><b>Anchor Bolt Analysis Summary:</b></p> <p>Static Load Case (105 mph):          Rotor Force @ 1'9" Ht = 665 lbf (2958 N)          Base Pole @ 4' Ht. = 92 lbf (409 N)</p> <p><b>PROVIDE: (4) 20mm diam. 'ISO 898-1' Class 8.8 A.B. with 23 inches min. Embed</b></p>
--



## Windspire Energy

5450 Louie Lane  
Reno, NV 89511  
[www.WindspireEnergy.com](http://www.WindspireEnergy.com)

Phone (775) 852-0200  
Fax (775) 201-0461

---

**Project** 30 FL WINDSPIRE (1.2KW)

**Code(s)** IBC 2006, ACI 318-08

**Item** Anchor Bolt Design

**Project No.** \_\_\_\_\_

**Designed**       DLM      



**Checked** \_\_\_\_\_

**Sheet** \_\_\_\_\_

**Date**       04/2010      

**Date** \_\_\_\_\_

---

FOUNDATION SECTION VIEW  
SCALE N.T.S.

FOUNDATION PLAN VIEW  
SCALE N.T.S.

---

**Foundation Anchor Bolt Design**

Resulting Forces (ASD)	
Shear ( $V_{20}$ ) =	0.665 k @ 19 ft
Shear ( $V_0$ ) =	0.092 k @ 4 ft
Shear ( $V_r$ ) =	0.757 k (4 bolts in shear)
Moment ( $M_0$ ) =	13.00 k*ft
$s_1$ =	8 in ...anchor bolt spacing
Tension ( $T$ ) =	19.50 k (2 bolts in tension)

---

**Anchor Bolt Steel Capacity**

ACI Sections D5.1 & D.6.1

<b>4</b>	of	<b>0.787</b>	Diam. ISO 898-1 Class 8.8 Anchor Bolts, $F_t = 0.33F_u$ ; $F_y = 0.17F_u$		
		A.B. allowable tension:	19.5 k/bolt	(ASD Value; Table I-B)	(ASD Value; Table I-D)
		A.B. allowable shear:	9.9 k/bolt	(ASD Value; Table I-B)	(ASD Value; Table I-D)
		$T_{ALLOW}$ =	38.9 k	<b>Tallow&gt;T =&gt; OK</b>	
		$V_{ALLOW}$ =	39.7 k	<b>Vallow&gt;V =&gt; OK</b>	

Tension & Shear = **0.3 < 1**      **COMBINED STRESS OK**

---

**Concrete Breakout Strength (Tension)**      **Required**

**Tension Development Length:**

ACI Section D.5.2 (RD.5.2.9 & Figure RD.5.2.9 - Anchor Reinforcement for Tension)

$l_{b\phi} =$  34 5/8 inches     $l_{b\phi} = 44"d_b$  (ACI 12.2.2, #6 Bar or smaller)

$T_{ALLOW}$  = 38.9 k


$T_{REQ'D}$  = 19.5 k

$l_{b\phi} = l_b^* (T_{ALLOW}/T_{REQ'D})$ ; Minimum of 12" (ACI 12.2.5)

$l_{b\phi} =$  17.4 inches

$l_{b\phi} =$  5.0 inches (horizontal distance to reinforcing)

**PROVIDE:**      **23" MIN OF LAP DISTANCE**

		<b>Windspire Energy</b> 5450 Louie Lane Reno, NV 89511 <a href="http://www.WindspireEnergy.com">www.WindspireEnergy.com</a>	Phone (775) 852-0200 Fax (775) 201-0465
Project	30 Ft. WINDSPIRE (1.2KW)	Designed No.	Sheet
Code(s)	IBC 2006, ACI 318-08	Designed <b>DLM</b>	Date <b>04/20/14</b>
Item	Anchor Bolt Design	Checked	Date

---

**Pullout Strength of Anchor in Tension**

ACI Section D.5.3

$\Psi_{c,LP} =$	1.0	...	Conservatively taken at 1.0 (cracked concrete)
$W_d =$	2.00	in	...washer diameter
$A_{brg} =$	2.7	in <sup>2</sup>	...Bearing area    Abrg = $\pi(W_d^2 \cdot Da^2)/4$
$f_{cp} =$	2500	psi	

---

$N_b =$	53103	lbs	...ACI Eq. D-15 $N_p = 8" \cdot A_{brg} \cdot f_c$
$N_{pn} =$	<b>39827</b>	lbs	...ACI Eq. D-14 $N_{pn} = \phi \Psi_{c,LP} \cdot N_p \quad (\phi = 0.75)$

$T_{MAX} =$	15604	lbs	...LRFD Factor Included (1.6) $T_{max} = 1.6 \cdot T^* / 2 \cdot 1000$
-------------	-------	-----	--

**Npn > Tmax => OK**

---

**Side-face Blowout Strength of Anchor in Tension**

ACI Section D.5.4

$c_{a1} =$	6	in	...edge distance (perp. to shear force)
$c_{a2} =$	6	in	...edge distance (parallel to shear force)
$\lambda =$	1.0		...Lightweight concrete factor (1.0 if normal weight)


---

$N_{b1} =$	3917	lbs	...ACI Eq. D-17 $N_{b1} = 160 \cdot C_{11} \cdot (A_{brg1})^{1/3} \cdot f_c^{1/4} \cdot (f_c')^{1/4} \cdot 5 \cdot (1 + c_{a2}/c_{a1})/4$
$N_{b2} =$	<b>35848</b>	lbs	...ACI Eq. D-18 $N_{b2} = \phi \cdot (1 + s/(8 \cdot c_{a1})) \cdot N_{b1} \quad (\phi = 0.75)$


  

$T_{MAX} =$	31207	lbs	...LRFD Factor Included (1.6) $T_{max} = 1.6 \cdot T^* / 2 \cdot 1000$
-------------	-------	-----	--


**Nsb > Tmax => OK**

		<b>Windspire Energy</b> 5450 Louie Lane Reno, NV 89511 <a href="http://www.MeriahPower.com">www.MeriahPower.com</a>	Phone (775) 582-0200 Fax (775) 201-0467
Project	30 Ft. WINDSPIRE (1.3KW)	Project No.	
Code(s)	IBC 2006, ACI 318-08	Designed	DLM
Item	Anchor Bolt Design	Checked	Date



FOUNDATION SECTION VIEW  
SCALE: N.T.S.



FOUNDATION PLAN VIEW  
SCALE: N.T.S.

---

**Concrete Break Strength of Anchor in Shear**

ACI Section D.6.2

$$V_{cbg} = (0.75) (A_{gc} / A_{cc}) (\Psi_{ecv}) (\Psi_{edn}) (\Psi_{cs}) (\Psi_{h, v}) V_o \quad (\text{ACI EQ. D-22})$$

$f'_c =$	<b>2500</b>	psi	
$P_{ho} =$	<b>24</b>	in	... Pole footing width perp. to shear force
$P_{lh} =$	<b>24</b>	in	... Pole footing height parallel to shear force
$P_{lh} =$	<b>36</b>	in	... Pole footing height
$h_a =$	<b>23</b>	in	... Anchor embed depth to bottom washer and double nut
$c_{s1} =$	<b>6</b>	in	... edge distance (perp. to shear force)
$s_{1s} =$	<b>8</b>	in	... spacing distance between bolts (perp. to shear force)
$c_{s2} =$	<b>6</b>	in	... edge distance (parallel, to shear force)
$s_{2s} =$	<b>8</b>	in	... spacing distance between bolts (parallel to shear force)
$A_{cc} =$	<b>216.0</b>	in <sup>2</sup>	... ACI Fig. RD. 6.2.1(c): $A_{cc} = (Pw) (1.5c_{s1})$
$A_{gc} =$	<b>162.0</b>	in <sup>2</sup>	... ACI Eq. D-23: $A_{gc} = 4.5(c_{s1})^2$
$V_o =$	<b>8963</b>	lbs	... ACI Eq. D-24: $V_o = (7(h_v/d_s)^{0.5} (d_s)^{0.5}) (f'_c)^{0.5} (c_{s1})^{1.5}$
$\Psi_{ecv} =$	<b>1.0</b>	...	... ACI Eq. D-26: concentric loading = 1.0
$\Psi_{edn} =$	<b>0.9</b>	...	... ACI Eq. D-28: $\Psi_{edn} = 0.7 + 0.3(f'_c / (1.5c_{s1}))$
$\Psi_{cs} =$	<b>1.4</b>	...	... ACI D.6.2.7 Reinf. of #4 or greater stirrups
$\Psi_{h, v} =$	<b>1.0</b>	...	... ACI D.6.2.8 $H_{sv} > 1.5' c_{s1}$

---

$V_{cbg} =$	<b>11293</b>	lbs	... Including $\phi = 0.75$
$V_{MAX} =$	<b>1064</b>	lbs	... Including Work Factor (1.6)

**Vcgb/Vmax == OK**

---

**Interaction of Tensile and Shear**

ACI Section D.7

**Full Tensile Strength Allowed - (20%Vcgb)-Vmax, ACI D.7.1**

PROVIDE: (4) 20mm diam. 'ISO 898-1' Class 8.8 A.B. with 23 inches min. Embed





Lateral Load Analysis  
For  
30 FOOT WINDSPIRE (1.2KW)

April 2, 2010

Prepared by:

Windspire Energy  
5450 Louie Lane  
Reno, NV 89511  
Phone: (775) 852-0200  
Fax: (775) 201-0467  
www.WindspireEnergy.com

Dennis Montgomery, P.E.  
NCEES #31559



Windspire Energy Proprietary & Confidential – Distribution allowed only with written approval of Windspire Energy.  
Intended for Windspire Energy Dealer's use in obtaining building permits and associated project approvals.



Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	As Stated	Designed	DLM	Date	04/2010
Item	Seismic Loads	Checked		Date	

Input	
Zip Code	ALL
Site Class	D

S <sub>s</sub> = 3.000	(Worst Case Design)
S <sub>1</sub> = 1.300	(Worst Case Design)
F <sub>a</sub> = 1.00	(Table 11.4-1 from ASCE 7)
F <sub>v</sub> = 1.50	(Table 11.4-2 from ASCE 7)
S <sub>MS</sub> = 3.000	$\frac{S_{MS}}{S_{M1}} = \frac{F_a S_s}{F_v S_1}$
S <sub>M1</sub> = 1.950	(Eqn's 11.4-1 & 11.4-2, ASCE 7)
S <sub>DS</sub> = 2.000	$\frac{S_{DS}}{S_{D1}} = \frac{2}{3} \frac{S_{MS}}{S_{M1}}$
S <sub>D1</sub> = 1.300	

Seismic Design Category (for seismic use group I, or II) => **F**

Input	
R = 2.5	(Table 12.2-1, ASCE 7)
I = 1.0	

W = 630 lbf	
H = 30 ft	
T = 0.43 s	(Eq. 12.8-7, ASCE 7)
C <sub>s max</sub> = 1.22	(Eq. 12.8-3, ASCE 7)
C <sub>s min</sub> = 0.26	(Eq. 12.8-6, ASCE 7)
C <sub>s</sub> = 0.800	(Eq. 12.8-2, ASCE 7)

V = 0.571 x W

V = 360 lbf

$$V' = \frac{C_s W}{1.4}$$
 modified for ASD



Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	As Stated	Designed	DLM	Date	04/2010
Item	Lateral Loading - Summary	Checked		Date	

Static Design Codes / Specifications':  
2006 International Building Code  
ASCE 7-05 - Minimum Design Loads for Buildings and Other Structures  
Wind Speed: 105 mph (47 m/s)  
Exposure Category: 'C'  
Structure Category: II  
Seismic S<sub>DS</sub>: 3.000  
Seismic S<sub>D1</sub>: 1.300

Dynamic Design Codes / Specifications':  
"MPG Report Analysis 2", Sept. 6, 2007, Dr. Ion Parashivoiu  
CARDAAV Code Analysis Software  
Wind Speed: 34 mph (15 m/s)  
Wind Speed Ref. Ht: 30 feet (9.144m)

Load Analysis Summary (Wind Governs - Lateral Loading):	
Static Load Case (105 mph):	
Rotor Force @ 20' Ht = 665 lbf (2958 N)	
Base Pole @ 5' Ht. = 92 lbf (409 N)	
Dynamic Load Case (34 mph, 15 m/s) - Cyclic Loading @ Rotational Components	
Rotor Force @ 20' Ht = 127 lbf (565 N)	

(1): Mechanical Brake is engaged at rotor revolutions greater than 400 rpm, approximately equal to 34 mph (15 m/s) wind speed as determined from CARDAAV Code Analysis. Therefore, wind speeds up to 34 mph (15 m/s) shall result in dynamic wind loads and wind speeds in excess of 34 mph (15 m/s) shall result in static wind loads.



Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006; ASCE 7-05	Designed	DLM	Date	04/2010
Item	Ice + Wind Load Calculation	Checked		Date	

Design: 50 MPH WIND, Static Design Wind Load Condition	
K <sub>z</sub> = 0.90	velocity pressure coefficient (from ASCE 7-05 Table 6-3) (Avg. rotor height = 20 ft. - Exposure 'C')
K <sub>at</sub> = 1.0	topographic factor (see ASCE 7-05 Section 6.5.7.2) K <sub>1</sub> = 0.0 K <sub>2</sub> = 1.0 K <sub>3</sub> = 1.0 (topographic effect - verify w/ site specific conditions)
K <sub>d</sub> = 0.85	wind directionality factor (from ASCE 7-05 Table 6-4) (Lattice Framework)
I = 1.0	Importance factor (from ASCE 7-05 Table 6-1) (Category II Structure)
V = 50 mph	3-second gust (Concurrent Wind Speed with Ice Loading)
q <sub>z</sub> = 4.9 psf	ASCE 7-05 Eq. 6-15 q <sub>z</sub> = 0.00256 K <sub>z</sub> K <sub>at</sub> K <sub>d</sub> V <sup>2</sup> I
G = 0.85	gust-effect factor (from ASCE 7-05 Section 6.5.8)
F = 4.2 * C <sub>f</sub> A <sub>f</sub> (lbs.)	ASCE 7-05 Eq. 6-28 F = q <sub>z</sub> G C <sub>f</sub> A <sub>f</sub>

Ice + Wind Load:


Ice Load:	
t = 1.0 in.	(ASCE 7-05, Figure 10-2)
l <sub>i</sub> = 1.0	
f <sub>i</sub> = 0.95	(ASCE 7-05, Eq. 10-4)
t <sub>d</sub> = 1.9 in.	(ASCE 7-05, Eq. 10-5)

Windspire Profile:

Airfoils = 10 in (total chord width profile)
Airfoils + Ice = 13.8 in (chord width + ice)
Ht. = 6.5 ft
# of Foils = 3
C <sub>f</sub> = 1.7 ...IEC 61400 Force Coefficients
V <sub>i</sub> = 13985 in <sup>2</sup> (ASCE 7-05, Eq. 10-2)




Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006; ASCE 7-05	Designed	DLM	Date	04/2010
Item	Wind Load Diagram	Checked		Date	



Static Loading

- 105 mph (3-sec. gust)
- \* Exposure 'C'
- \* Category II Structure



Dynamic (Cyclic) Loading

- \* Extrapolated Dynamic Wind Force, "MPG Report Analysis 2"
- \* 34 mph (15 m/s) Dynamic Wind Speed @ 400 rpm



Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006; ASCE 7-05	Designed	DLM	Date	04/2010
Item	Ice + Wind Load Calculation	Checked		Date	

Windspire Profile (Cont.):

Rotor Center Pole = 3.5 in (diam.)
Center Pole + Ice = 7.3 in (diam. + ice)
Ht. = 20 ft
C <sub>f</sub> = 1.3 ...IEC 61400 Force Coefficients
V <sub>i</sub> = 15771 in <sup>2</sup> (ASCE 7-05, Eq. 10-2)
Airfoil Struts = 0.25 in (thickness)
Airfoil Struts + Ice = 2.5 in (chord width + ice)
Length = 2.9 ft
# of Struts = 8.0 (including top and bottom safety rings)
C <sub>f</sub> = 1.5 ...IEC 61400 Force Coefficients
V <sub>i</sub> = 4238 in <sup>2</sup> (ASCE 7-05, Eq. 10-2)
Base Pole = 8.625 in (diam.)
Base Pole + Ice = 12.4 in (diam. + ice)
Ht. = 10.0 ft
C <sub>f</sub> = 0.7 ...IEC 61400 Force Coefficients
V <sub>i</sub> = 19354 in <sup>2</sup> (ASCE 7-05, Eq. 10-2)
Σ V <sub>i</sub> = 31 ft <sup>2</sup>
Σ W <sub>i</sub> = 1729 lbs. (Vertical)

Rotor Force = 257 lbs @ 20' Ht. (19' from steel base plate)
Base Pole Force = 30 lbs @ 5' Ht. (4' from steel base plate)



3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682

License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA


Date 7 . 14 . 15

LATERAL  
ANALYSIS

WT-7

LATERAL ANALYSIS



		<b>Windspire Energy</b> 5450 Louie Lane Reno, NV 89511 <a href="http://www.WindspireEnergy.com">www.WindspireEnergy.com</a>		Phone (775) 852-0200 Fax (775) 201-0467	
Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	CARDAAV Analysis Software	Designed	<u>DLM</u>	Date	<u>04/2010</u>
Item	Dynamic Wind Load Calculation	Checked		Date	

## TOWER ANALYSIS







Tower Analysis  
For  
30 FOOT WINDSPIRE (1.2KW)  
April 2, 2010

Prepared by:

Windspire Energy  
5450 Louie Lane  
Reno, NV 89511  
Phone: (775) 852-0200  
Fax: (775) 201-0467  
www.WindspireEnergy.com



Dennis Montgomery, P.E.  
NCEES #31559

Windspire Energy Proprietary & Confidential – Distribution allowed only with written approval of Windspire Energy.  
Intended for Windspire Energy Dealer's use in obtaining building permits and associated project approvals.



Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006	Designed	DLM	Date	04/2010
Item	Tower Design	Checked		Date	

Base Plate Design Per AISC - Design Guide 1:

P = 0.60 K  
f<sub>c</sub> = 2.50 ksi  
Base Plate Width (N=B) = 10.00 in (square)

F<sub>p</sub> = 1.75 ksi ... = 0.7\*f<sub>c</sub>  
M + PA' = 158 in\*kip ... (Assume A' = 4")  
F<sub>p</sub>\*B\*N<sup>2</sup> = 1264 in\*kip ... (Assume N' = 8.5")  
B = 0.125 ... = (M+PA')/(F<sub>p</sub>\*B\*N<sup>2</sup>)  
A/N' = 0.300 ... (Figure 16)  
A = 2.550 in ... = (A/N')\*N'  
α = 0.9 ... (Figure 16)  
T = 20.1 kips ... = (M+P\*A')/(α\*N') - P  
D<sub>cr</sub> = 0.90 in ... = (B-0.95\*OD)/2  
σ<sub>t</sub> = 1.278 ksi ... = (F<sub>p</sub>/A)\*(OD/2-(N/2-A))  
M<sub>PL</sub> = 0.65 in\*kip/in ... = (σ<sub>t</sub>\*D<sub>cr</sub><sup>3</sup>)/2+((F<sub>p</sub>-σ<sub>t</sub>)\*D<sub>cr</sub><sup>2</sup>\*0.67)/2

Min. Base Plate (t<sub>b</sub>) = 0.38 in ... = ((6\*M<sub>PL</sub>)/(0.75\*f<sub>y</sub>P<sub>L</sub>))<sup>0.5</sup>

Provide: ASTM A500 Grade B, 8.625" x 0.188" Wall Tower w/ 0.188" Fillet Weld  
1" x 10" x 10" ASTM A36 Steel Base Plate




Fig. 16. Design Aid for Axial Load Plus Moment

**Windspire Energy**  
5450 Louie Lane  
Reno, NV 89511  
www.WindspireEnergy.com

Phone (775) 852-0200  
Fax (775) 201-0467

Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	As Stated	Designed	DLM	Date	04/2010
Item	Tower Design	Checked		Date	

Design Codes / Specifications:  
2006 International Building Code  
AISC Steel Column Base Plate Design Guide 1  
ASCE 7-05 - Minimum Design Loads for Buildings and Other Structures  
Wind Speed: 105 mph (47 m/s)  
Exposure Category: 'C'  
Structure Category: II  
Tower Steel & Weld Material (AISC-Allowable Stress Design)  
Steel Tower: ASTM A500 B (f<sub>y</sub> = 42 ksi, f<sub>u</sub> = 58 ksi, min.)  
Weld Filler Material: E70xx (f<sub>y</sub> = 70 ksi)  
Steel Base Plate: ASTM A36

Pole Foundation Analysis Summary:  
Static Load Case (105 mph):  
Rotor Force @ 20' Ht = 665 lbf (2958 N)  
Base Pole @ 5' Ht. = 92 lbf (409 N)  
  
Tower Size, Base Weld, & Base Plate:  
Provide: ASTM A500 Grade B, 8.625" x 0.188" Wall Tower w/ 0.188" Fillet Weld  
1" x 10" x 10" ASTM A36 Steel Base Plate

**Windspire Energy**  
5450 Louie Lane  
Reno, NV 89511  
www.WindspireEnergy.com

Phone (775) 852-0200  
Fax (775) 201-0467


Project	30 Ft. WINDSPIRE (1.2KW)	Project No.		Sheet	
Code(s)	IBC 2006	Designed	DLM	Date	04/2010
Item	Tower Design	Checked		Date	

Tower Stress:  
Shear (V<sub>20</sub>) = 0.665 k @ 19 ft  
Shear (V<sub>3</sub>) = 0.092 k @ 4 ft  
Static Moment (M<sub>T</sub>) = 13.00 k\*ft  
Dynamic Moment (M<sub>D</sub>) = 0.42 k\*ft ... (Rotordynamic Analysis, Attached)

Tower O.D. = 8.625 in  
Tower I.D. = 8.249 in  
I<sub>T</sub> = 44.36 in<sup>4</sup> ... = π\*(OD<sup>4</sup>-ID<sup>4</sup>)/64  
σ<sub>T</sub> = 15.17 ksi ... = M<sub>T</sub>\*12\*(OD/2)/I<sub>T</sub>  
σ<sub>D</sub> = 0.49 ksi ... = M<sub>D</sub>\*12\*(OD/2)/I<sub>T</sub>

Allowable σ<sub>T</sub> = 25.20 ksi ... = 0.6(f<sub>y</sub>)  
Allowable σ<sub>D</sub> = 2.50 ksi ... (AWS D14.4, Table 5)

8.625x0.188 Wall Tower OK





Weld Stress:  
S<sub>w</sub> = 61.00 in<sup>2</sup> ... = π\*(OD/2+W<sub>T</sub>/2)<sup>2</sup>  
σ<sub>WT/in</sub> = 2.56 k/in ... = M<sub>T</sub>\*12/S<sub>w</sub>  
σ<sub>WD/in</sub> = 0.08 k/in ... = M<sub>D</sub>\*12/S<sub>w</sub>

Weld Thickness (W<sub>T</sub>) = 0.188 in

Allowable σ<sub>WT/in</sub> = 2.79 k/in ... = 0.707\*0.3\*W<sub>T</sub>\*70  
Allowable σ<sub>WD/in</sub> = 0.47 k/in ... = (2.5 ksi)\*W<sub>T</sub>

Base Weld OK

A. STANDARD UNIT WITH FABREEKA WASHERS:  
Whirl Amplitudes and Dynamic Loads at the Base Plate



TOWER ANALYSIS



3811 Dividend Drive, Suite D  
Shingle Springs, CA 95682  
License Number: 950064  
www.energystarsconstruction.com

Grant Gluck  
916.275.3559  
grant@energystarsconstruction.com

idec  
1175 Elko Dr.  
Sunnyvale, CA

Date 7 . 14 . 15

/ TOWER  
ANALYSIS

WT-9