Conditional Use Permit - Risk Assessment

Tulip Kids, Inc. 1271 Lawrence Station Road Sunnyvale, CA 94089

Project Number: PR-000583 Document Number: Draft A

Date Prepared: June 1, 2016



Prepared by:

899 Pine Street #1401 San Francisco, CA 94108 (415) 992-7458

OTIS INSTITUTE

Table of Contents

Table of Contents i
Section One ii
Overviewii
Recommended Conditions of Approvaliii
Limitationsiii
Section Two 1
Project Overview1
Section Three 2
Primary Land Use2
Industrial activities in the neighborhood
Potential Chemicals of Concern Inventory
Section Four 3
Review of Historical Hazmat Incidents3
Section Five 4
Risk Evaluation: Release Scenarios and Discussions4
Pure Substances
Mixtures
Attachment One 7
Sites with potential Chemicals of Concern7
Attachment Two 9
ALOHA Printouts9
Attachment Three 10
ARCHIE and SCREEN3 Printouts 10

Section One

Overview

This is an engineering report of the Otis Institute Inc.'s opinions and conclusions regarding the potential exposure to hazardous materials which may occur at the Tulip Kids Preschool Center due to its location in an industrial zone. Based on:

- The Industrial Activity Screening in the Area (2500 feet radius),
- The Hazardous Material Inventory Statement provided by the Sunnyvale Department of Public Health on May 26, 2016,
- The Worst-Case Gas Release Modeling,
- The Planner's Guidelines for Preparation of Risk Assessments,

no chemicals were identified as potential chemicals of concern (COC) during a worst case release scenario that may have negative environmental impacts at the 1271 Lawrence Station Road project site.

The risk assessment concludes that the Tulip Kids Preschool Center is not within 1/10th IDLH level (Immediately Dangerous to Life and Health) of a COC, and that mitigation measures are not required. However, recommendations for the emergency action plan and parental disclosure are listed on the next page and will provide added safeguards to reduce the potential impact of a toxic chemical release in the area.

This report and its documented results were produced by Troy Christensen, PE and Emilie Cherre, EHS Consultant.

in (Signature)

Troy Christensen, PE 06/01/2016 (Name) - (Date)

<u>California – C64870 Expires – 06/30/2017</u> (State of Registration) - (Registration Number)



Recommended Conditions of Approval

The following is recommended to reduce the potential impact of a toxic chemical release in the area:

- 1. Implementing an Emergency Action Plan (EAP) with Evacuation and Shelter in Place procedures. The EAP shall include training of employees and drills to verify the emergency systems described below are well understood. A test shall be administered to verify the competence of employees.
- 2. Installing a wind directional sock on the building for assessing wind direction and weather conditions.
- 3. Implementing an in-place communication system for notifying occupants via a prerecorded message in the event of an incident, and directing them regarding emergency procedures to follow.
- 4. Verifying locations and existence of all manual shutoff controls for the building ventilation system.
- 5. Implementing a parental notification process including a description of how each parent will be notified of the nature of hazards in the area. This shall include at minimum:
 - a. A notification that includes the emergency procedures in place to protect their children, and what procedures the parents need to follow in the event of each type of anticipated emergency.
 - b. Notification records are to be maintained, signed by parents, stating that they understand and accept the emergency procedures that are in place.

Limitations

This Risk Assessment Report has been prepared by Otis Institute's consultants who have over 20 years of chemical release risk assessment experience. They are knowledgeable about industrial manufacturing processes, including the types of hazardous materials used in the processes that were evaluated in this assessment. This report has been prepared based on information provided by the Sunnyvale Department of Public Health and the Tulip Kids Preschool Center in May 2016.

No modeling assessment can wholly eliminate uncertainty regarding the impact to the site from accidental and catastrophic releases of hazardous materials. This threat zone modeling is intended to reduce, but not eliminate, uncertainty regarding the potential for impacts to the site from such catastrophic releases. The primary uncertainties associated with this appraisal included the selection of facilities and chemicals for evaluation, the size of each release, assumptions concerning release location, vapor pressures of released liquids, assumed area of liquid spills, and atmospheric conditions during the release.

No warranty, expressed or implied, is made. In the event that changes in the nature, use, or layout of the facility, or in the chemical usage of the facilities around 1271 Lawrence Station Road be valid. This evaluation is valid for one year.

Section Two

Project Overview

Tulip Kids, Inc. plans to open a Preschool Center serving children aged two to five years on the lower floor of an existing mixed-use building located at 1271 Lawrence Station Road in Sunnyvale, California. The Childcare Center would operate from 8:00 am to 6:00 pm with a capacity of 85 children and 11 teachers and supporting staff members.

Figure 1: Tulip Kids Preschool Center - Circles at 2500 feet



Section Three

Primary Land Use

Industrial activities in the neighborhood

Within a 2,500 feet radius (0.5 miles), the Otis Institute investigated businesses in the area of the 1271 Lawrence Station Road location, to determine a list of companies in the area who might use toxic and corrosive gases in the proposed preschool neighborhood. To screen all industrial activities, the Otis Institute used:

- 1. Envirostor, which provides a list of tiered permit sites <u>http://www.envirostor.dtsc.ca.gov/public/</u>
- Hazardous Waste Traking System Reports, which provide a list of hazardous waste generators – <u>http://hwts.dtsc.ca.gov/report_search.cfm?id=5</u>
- 3. Google Map Search with key words such as: Semiconductor, Electronics, Manufacturing, Chemical, Plating, Waste, etc.

The Otis Institute submitted the list to the Sunnyvale Department of Public Health on Thursday May 26, 2016. The CUPA technical assistant searched for each address to determine whether or not the company had an active CERS Inventory. The Otis Institute was provided with Hazardous Material Inventory Statements on that same day.

Potential Chemicals of Concern Inventory

From a risk assessment perspective, the primary emphasis is to identify chemicals that are likely to have significant off-property consequences if catastrophically released. Generally, chemicals that are acutely toxic, exist in a form that readily allows offproperty transport (after release), and are used/stored in sufficient quantities are assumed to represent potential Chemicals of Concern (COCs).

This evaluation determined that the following organizations had chemicals that may environmentally impact the 1271 Lawrence Station Road proposed site:

- 1. LABPRO 1290 Anvilwood Court
- 2. WESTAK/QUALITEK, INC. 1274/1276 Forgewood Avenue
- 3. UPS 1245 Hammerwood Avenue
- 4. SUNNYVALE AUTO BODY 1281/1288 Forgewood Avenue
- 5. KRYTAR 1288 Anvilwood Avenue
- 6. CHEVRON STATION 1265 Lawrence Station Road
- 7. CYTYC CORP 1240 Elko Drive
- 8. ERC CONCEPTS CO 1255 Birchwood Drive
- 9. ARVI MANUFACTURING CO 1256 Birchwood Drive

Attachment One contains a spreadsheet documenting the results of the HMIS review, chemicals of concern, distance to the 1271 Lawrence Station Road location, maximum amount of the chemical onsite, units of measure, and largest container of chemical onsite.

Section Four

Review of Historical Hazmat Incidents

The Otis Institute completed a review of historical incidents involving chemicals of concern listed in Attachment One, and most particularly Acetylene or Gasoline. This determination including incident reviews documented by the:

- US Chemical Safety Board (CSB)
- San Jose Mercury Archives
- Google Search
- City of Sunnyvale Website

Reviews went back to 2006-2016, depending on the source searched, and no incidents had been documented in any of the City of Sunnyvale public records available from these sources. Furthermore, no incident has been recorded in nearby communities with potential for off site consequences.

Section Five

Risk Evaluation: Release Scenarios and Discussions

Pure Substances

The largest container of each chemical of concern was evaluated to determine the possible off-site consequence during a catastrophic release, and if the release could have a potential negative environmental impact at the 1271 Lawrence Station Road site. Each release was evaluated as to whether a release would produce concentrations of the chemical at the project site at $1/10^{\text{th}}$ of the established 'Immediately Dangerous to Life and Health' (IDLH) level, with no engineering controls in place.

This off-site consequence determination was modeled using a software program: ALOHA (Areal Locations of Hazardous Atmospheres) Version 5.4.6, to determine potential worstcase release scenarios and distances. ALOHA is a modeling program provided by the USEPA, which estimates threat zones associated with hazardous chemical releases, including toxic gas clouds, fires, and explosions. A threat zone is an area where a hazard (such as toxicity, flammability, thermal radiation, or damaging overpressure) has exceeded a user-specified Level of Concern (LOC).

The worst-case release scenarios used the requirements listed in the California Accidental Release Prevention (CalARP) guidance and EPA Risk Management Program guidance documentation.

Based on ALOHA dispersion modeling and assumptions, only one scenario was retained:

Acetylene Cylinder rupture

Note that five sites out of the nine selected have acetylene cylinders used for welding, cutting and similar processes on their property. Thus, the threat zone for acetylene release was modeled for ERC CONCEPTS CO, which is the closest business (1100 feet), with the largest container (200 Cu. Feet) on site. Below is shown the list of businesses storing and using acetylene.

Facility Name	Distance to Site	Max. Quantity	Larger Container	Unit
WESTAK/QUALITEK, INC.	1400 ft	400	200	Cu. Feet
UPS	1750 ft	500	125	Cu. Feet
SUNNYVALE AUTO BODY	1450 ft	385	130	Cu. Feet
KRYTAR	1100 ft	35	35	Cu. Feet
ERC CONCEPTS CO	1100 ft	200	200	Cu. Feet
ARVI MANUFACTURING CO	1350 ft	114	115	Cu. Feet

Tulip Kids, Inc. - Conditional Use Permit - Risk Assessment Project Number: PR-000583

Release Type: Instantaneous - occurs when the chemical escapes into the atmosphere within a minute

Release Duration: 1 minute

Amount of Chemical Entering Atmosphere: 200 Cu. Feet

Source Height: 0 – Ground level

Volume Input: Chemical stored as a gas, Temperature: 70 degrees Fahrenheit, Pressure: 250 psia

Wind Speed: 1.5 meters per second

Topography: Urban

Atmospheric Stability Class: F (stable conditions)

The ALOHA results of catastrophic acetylene releases are documented below and ALOHA printouts are shown in Attachment Two.

Chemical Name	Larger Container (Cu. Feet)	IDLH (ppm)	1/10 IDLH (ppm)	Distance to IDLH (Feet)	Distance 1/10 IDLH (Feet)	Distance to School (Feet)
Acetylene	200	2500 ppm	250 ppm	711 feet	2046 feet	1100 feet

However, given the wide explosive limit of acetylene, an instantaneous release of the entire content of the cylinder within a minute will not lead to a toxic gas release as modeled above: Instead, most likely a torch fire will result of the escaping gas, if not an explosion.

Both flammable and overpressure (blast force) threat zone are shown in Attachment Two. None of these zones do reach the proposed site.

Discussion and conclusion:

The probability for the acetylene tank failure is 1×10^{-6} per year, based on the catastrophic failure rate of acetylene stored in a gas cylinder resulting in an instantaneous release of the entire contents of the tank and thereby having the total vapor mass involved in the explosion (Purple Book, 2005). Then, in case of a tank failure with complete mixing at Upper Flammability Limit (UFL) upon release, an instantaneous release of the entire content of the cylinder will not lead to a toxic gas release but to a flammable torch or explosion, whose consequences will not have a potential negative environmental impact at the 1271 Lawrence Station Road site.

Mixtures

Gasoline Spill

Located approximately 300 feet from the site, the most significant hazardous material reported at the CHEVRON facility is a 10,000 gallon underground storage tank of gasoline.

The worst-case release from this facility hypothetically would assume that 5,000 gallons of gasoline is released during a tank refill, and the evaporating pool would generate flammable vapors for approximately 30 minutes (assuming emergency response within 30 minutes).

This release is unique in that gasoline formulations are composed of hundreds of different hydrocarbon compounds, and the assumed volume of spilled material is great. ALOHA can model pure substances and has limited capabilities with respect to large volumes released. Therefore, this release was modeled in two ways. First, the Automated Resource for Chemical Hazard Incident Evaluation (ARCHIE) was used to estimate the release rate from an evaporating pool and the potential consequences of a vapor cloud explosion. However, since ARCHIE does not offer a choice for either urban or rural dispersion conditions, U.S. EPA SCREEN3 was also used to estimate off-site consequences for an area source using urban dispersion conditions.

These dispersion models determined that the proposed preschool would be within the toxic threat zone in the eventuality that the spill is fully vaporized abd does not ingnite.

If the gasoline has completely vaporized and vapors did not disperse before finding an ignition source, the unconfined vapor cloud explosion effects would be:

- Range serious/slight injuries from flying glass/object.
- Partial collapse of home walls/roofs.

ARCHIE and SCREEN3 printouts are shown in Attachment Three.

Discussion and conclusion:

In our opinion, this release scenario is highly unlikely. The most common spills occur at the fill pipe when the delivery hose is disconnected. These spills tend to be small (the typical delivery hose can hold approximately 14 gallons of fuel) and easily prevented. In addition, Underground Storage Tanks are designed with catchment basins to contain such spills. Fuel deliverers are trained to follow the industry standard practices for tank filling (API Recommended Practice 1007, "Loading and Unloading of MC306 DOT 406 Cargo Tank Motor Vehicles" and NFPA 385 "Standard for Tank Vehicles for Flammable and Combustible Fuels"). Based on the large number of daily fuel deliveries throughout the Bay Area, the lack of readily available information of such catastrophic releases (5,000 gallons) of this nature actually occurring during filling operations, and the high level of training and procedural requirements for gasoline deliveries, Otis Institute did not retained this scenario.

Conclusion

The nine facilities identified as facilities of potential concern (Attachment One) do not appear to pose unacceptable risks to the proposed use of the Site, in our opinion.

Attachment One

Sites with potential Chemicals of Concern

Tulip Kids, Inc. - Conditional Use Permit - Risk Assessment

Project Number: PR-000583

No	Facility Name	Type of Industrial Activity	Address	Distance to Site	Chemicals	State	Max. Quantity	Larger Container	Unit	Fire Haz. Class	IDLH
					Tetrahydrofuran	Liquid	20	5	Gallons	Flammable, Irritant, Sensitizer	2000 ppm
					Acetone	Liquid	120	1	Gallons	Flammable, Irritant	20,000 ppm
		Distributor of laboratory products,			Chloroform	Liquid	50	8	Pounds	Carcinogen, Irritant, Other Health Hazard	500 ppm
Ţ	LADPRO	microscopes and		1250 H	Hydrofluoric Acid 49%	Liquid	600	10	Pounds	Toxic, Corrosive	30 ppm
		imaging equipment			Hydrogen Peroxide	Liquid	80	1	Gallons	Flammable, Irritant, Other Health Hazard	75 ppm
					Isopropanol	Liquid	200	1	Gallons	Flammable	2000 ppm
					Nitric Acid	Liquid	470	7	Pounds	Corrosive, Oxidizing	25 ppm
	WESTAK/ QUALITEK, INC.	Printed and Etched Circuits Manufacturer	1274/1276 Forgewood Avenue		Acetylene	Gas	400	200	Cu. Feet	Unstable, Flammable	2500 ppm
2				1400 ft	Hydrochloric Acid	Liquid	30	1	Gallons	Corrosive, Other Health Hazard	50 ppm
					Hydrogen Peroxide 30- 50%	Liquid	150	50	Gallons	Corrosive, Oxidizing, Unstable	75 ppm
	UPS	Printing and Delivery Services	1245 Hammerwood Avenue	1750 ft	Acetylene	Gas	500	125	Cu. Feet	Unstable, Flammable	2500 ppm
3					Diesel	Liquid	18,000	10,000	Gallons	Flammable	-
					Gasoline	Liquid	9,000	10,000	Gallons	Flammable	-
4	SUNNYVALE AUTO BODY	Auto Body Repair	1281/1288 Forgewood Avenue	1450 ft	Acetylene	Gas	385	130	Cu. Feet	Unstable, Flammable	2500 ppm
5	KRYTAR	Microwave Components	1288 Anvilwood Avenue	1100 ft	Acetylene	Gas	35	35	Cu. Feet	Unstable, Flammable	2500 ppm
6	CHEVRON STATION	Gas Station	1265 Lawrence Station Road	300 ft	Gasoline	Gas	20,000	10,000	Gallons	Flammable	-
7	CYTYC CORP	Medical Device Manufacturer	1240 Elko Drive	2000 ft	Diesel Fuel	Liquid	180	180	Gallons	Flammable	-
8	ERC CONCEPTS CO	Machine shop	1255 Birchwood Drive	1100 ft	Acetylene	Gas	200	200	Cu. Feet	Unstable, Flammable	2500 ppm
9	ARVI MANUFACTURING CO	Roofing Siding and Sheet Metal Work	1256 Birchwood Drive	1350 ft	Acetylene	Gas	114	115	Cu. Feet	Unstable, Flammable	2500 ppm

Attachment Two

ALOHA Printouts

Attachment 10

Toxic Threat Zone

```
Time: May 27, 2016 & 1655 hours PDT (using computer's clock)
Chemical Name: ACETYLENE
Wind: 1.5 meters/second from s at 3 meters
THREAT ZONE:
Model Run: Heavy Gas
Red : 275 yards --- (2500 ppm)
Orange: 774 yards --- (250 ppm)
```







ALOHA® 5.4.6

ALOHA® 5.4.6

SITE DATA: Location: SUNNYVALE, CALIFORNIA Building Air Exchanges Per Hour: 0.31 (unsheltered single storied) Time: May 27, 2016 & 1655 hours PDT (using computer's clock) CHEMICAL DATA: Chemical Name: ACETYLENE CAS Number: 74-86-2 Molecular Weight: 26.04 g/mol PAC-2: 230000 ppm PAC-1: 65000 ppm PAC-3: 400000 ppm UEL: 800000 ppm LEL: 25000 ppm Ambient Boiling Point: -119.1° F Vapor Pressure at Ambient Temperature: greater than 1 atm Ambient Saturation Concentration: 1,000,000 ppm or 100.0% ATMOSPHERIC DATA: (MANUAL INPUT OF DATA) Wind: 1.5 meters/second from s at 3 meters Ground Roughness: urban or forest Cloud Cover: 5 tenths Air Temperature: 70° F Stability Class: F (user override) No Inversion Height Relative Humidity: 50% SOURCE STRENGTH: Direct Source: 200 cubic feet Source Height: 0 Source State: Gas Source Temperature: equal to ambient Source Pressure: 250 psia Release Duration: 1 minute Release Rate: 4.32 pounds/sec Total Amount Released: 259 pounds THREAT ZONE: Model Run: Heavy Gas Red : 275 yards --- (2500 ppm) Orange: 774 yards --- (250 ppm)

Attachment 10

Flammable Threat Zone

Time: May 31, 2016 & 1644 hours PDT (using computer's clock)
Chemical Name: ACETYLENE
Wind: 1.5 meters/second from s at 3 meters
THREAT ZONE:
 Threat Modeled: Flammable Area of Vapor Cloud
 Model Run: Heavy Gas
 Red : 57 yards --- (25000 ppm = LEL)
 Orange: 300 yards --- (2500 ppm = 10% LEL)







yards

greater than 25000 ppm (LEL) greater than 2500 ppm (10% LEL) wind direction confidence lines

ALOHA® 5.4.6

SITE DATA: Location: SUNNYVALE, CALIFORNIA Building Air Exchanges Per Hour: 0.31 (unsheltered single storied) Time: May 31, 2016 & 1644 hours PDT (using computer's clock) CHEMICAL DATA: Chemical Name: ACETYLENE CAS Number: 74-86-2 Molecular Weight: 26.04 g/mol PAC-2: 230000 ppm PAC-1: 65000 ppm PAC-3: 400000 ppm UEL: 800000 ppm LEL: 25000 ppm Ambient Boiling Point: -119.1° F Vapor Pressure at Ambient Temperature: greater than 1 atm Ambient Saturation Concentration: 1,000,000 ppm or 100.0% ATMOSPHERIC DATA: (MANUAL INPUT OF DATA) Wind: 1.5 meters/second from s at 3 meters Ground Roughness: urban or forest Cloud Cover: 5 tenths Air Temperature: 70° F Stability Class: F (user override) No Inversion Height Relative Humidity: 50% SOURCE STRENGTH: Direct Source: 200 cubic feet Source Height: 0 Source State: Gas Source Temperature: equal to ambient Source Pressure: 250 psia Release Duration: 1 minute Release Rate: 4.32 pounds/sec Total Amount Released: 259 pounds THREAT ZONE: Threat Modeled: Flammable Area of Vapor Cloud Model Run: Heavy Gas Red : 57 yards --- (25000 ppm = LEL) Orange: 300 yards --- (2500 ppm = 10% LEL)

Attachment 10

Overpressure (Blast Force) Threat Zone

```
Time: May 31, 2016 & 1644 hours PDT (using computer's clock)
Chemical Name: ACETYLENE
Wind: 1.5 meters/second from s at 3 meters
THREAT ZONE:
  Threat Modeled: Overpressure (blast force) from vapor cloud explosion
  Type of Ignition: ignited by spark or flame
  Level of Congestion: congested
  Model Run: Heavy Gas
  Red  : 66 yards --- (8.0 psi = destruction of buildings)
  Orange: 84 yards --- (1.0 psi = shatters glass)
```



 ŀ
ļ

greater than 8.0 psi (destruction of buildings) greater than 3.5 psi (serious injury likely) greater than 1.0 psi (shatters glass) wind direction confidence lines ALOHA® 5.4.6

ALOHA® 5.4.6

SITE DATA: Location: SUNNYVALE, CALIFORNIA Building Air Exchanges Per Hour: 0.31 (unsheltered single storied) Time: May 31, 2016 & 1644 hours PDT (using computer's clock) CHEMICAL DATA: Chemical Name: ACETYLENE CAS Number: 74-86-2 Molecular Weight: 26.04 g/mol PAC-2: 230000 ppm PAC-1: 65000 ppm PAC-3: 400000 ppm UEL: 800000 ppm LEL: 25000 ppm Ambient Boiling Point: -119.1° F Vapor Pressure at Ambient Temperature: greater than 1 atm Ambient Saturation Concentration: 1,000,000 ppm or 100.0% ATMOSPHERIC DATA: (MANUAL INPUT OF DATA) Wind: 1.5 meters/second from s at 3 meters Ground Roughness: urban or forest Cloud Cover: 5 tenths Air Temperature: 70° F Stability Class: F (user override) No Inversion Height Relative Humidity: 50% SOURCE STRENGTH: Direct Source: 200 cubic feet Source Height: 0 Source State: Gas Source Temperature: equal to ambient Source Pressure: 250 psia Release Duration: 1 minute Release Rate: 4.32 pounds/sec Total Amount Released: 259 pounds THREAT ZONE: Threat Modeled: Overpressure (blast force) from vapor cloud explosion Type of Ignition: ignited by spark or flame Level of Congestion: congested Model Run: Heavy Gas : 66 yards --- (8.0 psi = destruction of buildings) Red Orange: 84 yards --- (3.5 psi = serious injury likely) Yellow: 185 yards --- (1.0 psi = shatters glass)

Attachment Three

ARCHIE and SCREEN3 Printouts

ARCHIE

PHYSIOCHEMICAL PROPERTIES OF MATER NORMAL BOILING POINT MOLECULAR WEIGHT LIOUID SPECIFIC GRAVITY	RIAL = 130 = 100 = .75	degrees F
VAPOR PRES AT AMBIENT TEMP LOWER FLAMMABLE LIMIT (LFL) LOWER HEAT OF COMBUSTION GAS EXPLOSION YIELD FACTOR TOXIC VAPOR LIMIT	= 5.01 = 258.7 = 1.3 = 19000 = .03 = 300	psia mm Hg vol% Btu/lb ppm
CONTAINER CHARACTERISTICS TEMP OF CONTAINER CONTENTS	= 70	degrees F
ENVIRONMENTAL/LOCATION CHARACTERIS AMBIENT TEMPERATURE WIND VELOCITY ATMOSPHERIC STABILITY CLASS LIQUID CONFINEMENT AREA VAPOR/GAS DISCHARGE HEIGHT	STICS = 80 = 3.4 = F = NONE = 0	degrees F mph feet
KEY RESULTS PROVIDED BY USER INSTE DISCHARGE RATE DURATION DISCHARGE AMOUNT DISCHARGED	EAD OF BY EVALUAT = 3335 = 10 = 33350	ION METHODS lb/min minutes lbs
KEY RESULTS OVERRIDDEN BY USER AT	SOME POINT AFTER	COMPUTATION

INPUT PARAMETER SUMMARY

NONE OBSERVED

****** LIQUID POOL SIZE ESTIMATES Evaporating pool area = 30949 ft2 Burning pool area = 3077 ft2 Note: Pool is assumed to ignite immediately upon initiation of discharge. ****** LIQUID POOL EVAPORATION RATE/DURATION ESTIMATES Vapor evolution rate = 2054.6 lbs/min Evolution duration = 16.3 minutes ****** TOXIC VAPOR DISPERSION ANALYSIS RESULTS Downwind distance to concentration of 300 ppm -- at groundlevel = 25953 feet Note: Minimum computable answer is 33 feet! Actual hazard distance may be less. See attached table(s) for further details. ****** FLAMMABLE VAPOR CLOUD HAZARD RESULTS For concentration of 1/2 LFL LFL -----Downwind hazard distance = 1066 733 feet Max hazard zone width = 959 660 feet Max weight explosive gas = 7314 5031 lbs Relative gas/air density = 1.84 1.84 initially Model used in analysis = Heavy gas ****** EXPLOSION HAZARDS: See attached table(s)

UNCONFINED VAPOR CLOUD EXPLOSION EFFECTS

DISTA	NCE FI	ROM	EXPLOSION	EXPECTED DAMAGE
	(fee	t)		
	894:	1	Occasior	nal breakage of large windows under stress.
	1260	0	Some dan	nage to home ceilings; 10% window breakage.
471	0.77	816	Windows	usually shattered; some frame damage.
	471		Partial	demolition of homes; made uninhabitable.
121	ान्त	471	Range se	erious/slight injuries from flying glass/object.
	284		Partial	collapse of home walls/roofs.
217	2 3.	284	Non-rein	nforced concrete/cinder block walls shattered.
97	3 	251	Range 90)-1% eardrum rupture among exposed population.
	244		50% dest	cruction of home brickwork.
181	-	217	Frameles	ss steel panel buildings ruined.
	158		Wooden u	utility poles snapped.
130	-	158	Nearly o	complete destruction of houses.
	107		Probable	e total building destruction.
64	-	89	Range fo due to d	or 99-1% fatalities among exposed populations lirect blast effects.

Note: The center of an unconfined gas/vapor explosion can be anywhere within the ground area passed over by the cloud or plume. See results of the vapor cloud fire hazard analysis for the maximum downwind distance and maximum width of this area. Explosion is assumed to take place on or near the ground. SCREEN

08/16/07 15:56:43

*** VERSION DATED 96043 *** Gasoline Release SIMPLE TERRAIN INPUTS: SOURCE TYPE AREA = EMISSION RATE $(G/(S-M^{**2})) =$ 5.40000 .0000 SOURCE HEIGHT (M) -LENGTH OF LARGER SIDE (M) = LENGTH OF SMALLER SIDE (M) = 53.6000 RECEPTOR HEIGHT (M) 2.0000 = URBAN/RURAL OPTION URBAN -----THE REGULATORY (DEFAULT) MIXING HEIGHT OPTION WAS SELECTED. THE REGULATORY (DEFAULT) ANEMOMETER HEIGHT OF 10.0 METERS WAS ENTERED.

MODEL ESTIMATES DIRECTION TO MAX CONCENTRATION

BUOY. FLUX = .000 M**4/S**3; MOM. FLUX = .000 M**4/S**2.

*** STABILITY CLASS 6 ONLY *** *** ANEMOMETER HEIGHT WIND SPEED OF 1.50 M/S ONLY ***

*** SCREEN3 MODEL RUN ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

	DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	MAX DIR (DEG)
-	100	22025,08		1 5	1 5	10000 0		 / C
	200	.2292E+08 8891F+07	6	1.5	1.5	10000.0	.00	45.
	300.	.4734E+07	ő	1.5	1.5	10000.0	.00	45.
	400.	.2975E+07	6	1.5	1.5	10000.0	.00	45.
	500.	.2070E+07	6	1.5	1.5	10000.0	.00	35.
	750.	.1080E+07	6	1.5	1.5	10000.0	.00	26.
	1000.	.6898E+06	6	1.5	1.5	10000.0	.00	1.
	440.	.2547E+07	6	1.5	1.5	10000.0	.00	37.

*** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION	MAX CONC	DIST TO	TERRAIN
PROCEDURE	(UG/M**3)	MAX (M)	HI (M)
SIMPLE TERRAIN	.2292E+08	100.	0.